



---

87 Hunt Road Orangeburg, NY 10962 • Ph: 888-616-3545 • Fax: 888-754-4304

## Sample Analysis

TO: Essex County College

Date: 3/18/24

Attention: Frank C/ Jeff Shapiro

Email:

---

Reference: Daycare Domestic Water  
Sampling P00222697

**Notes:**

- *Hach Chlorine DPD Method used to test chlorine concentrations*
- *Free/Total chlorine levels are within acceptable limits for drinking water quality*

Any questions please do not hesitate to reach out.

Jack Sheehan  
Account Manager  
C: 215-622-5495  
jsheehan@claritywatertech.com



	<b>Free Chlorine (ppm)</b>	<b>Total Chlorine (ppm)</b>
Room 313: Sink 1	0.27	0.83
Room 313: Sink 2	0.33	0.90
Room 313: Sink 3	0.40	0.62
Room 314: Sink 1	0.37	0.49
Room 314: Sink 2	0.29	0.55
Room 314: Sink 3	0.38	0.49
Room 315: Sink 1	0.20	0.33
Room 315: Sink 1	0.31	0.40
Room 315: Sink 2	0.22	0.57
Room 316: Sink 3	0.24	0.60
Room 316: Sink 1	0.30	0.55
Room 316: Sink 2	0.27	0.44
Room 317: Sink 3	0.18	0.58
Room 317: Sink 3	0.11	0.39
Room 317: Sink 3	0.21	0.30
Kitchen Sink 1	0.44	0.70
307 RR Sink	0.38	0.55
308 RR Sink	0.28	0.34
304 Water Cooler	0.50	0.66
305 Sink	0.38	0.70