



FINAL REPORT

Clarity Water Technologies

87 Hunt Road
Orangeburg, NY 10962
P: (845) 589-0580

Account #: 5732
SPL Project ID: 2607-00280
Project Name: Essex County College
Sampled By: James Kelly
Date Received: 07/07/2026
Date Final: 07/24/2026

Summary

This summary is provided for your convenience. Complete report on the following pages.

Lead

Location	Result	Concentration
1. Room 313 Sink 1	Complete	0.0014 mg/L
2. Room 313 Sink 2	Complete	<0.0010 mg/L
3. Room 314 Sink	Complete	0.0019 mg/L
4. Room 315 Sink	Complete	0.0016 mg/L
5. Room 316 Sink	Complete	<0.0010 mg/L
6. Room 316 Sink 2	Complete	0.0220 mg/L
7. Room 317 Sink 1	Complete	0.0042 mg/L
8. Room 317 Sink 2	Complete	0.0014 mg/L
9. Kitchen Sink 1	Complete	<0.0010 mg/L
10. Kitchen Sink 2	Complete	0.0041 mg/L
11. Kitchen Sink 3	Complete	<0.0010 mg/L
12. Room 307	Complete	<0.0010 mg/L
13. Room 308 RR Sink	Complete	0.0051 mg/L
14. Room 304 Water Cooler	Complete	<0.0010 mg/L
15. Room 305 Sink	Complete	0.0032 mg/L

Approved By: Erika Egeler

Dr. Michael Berg
Laboratory Director



FINAL REPORT

Clarity Water Technologies

87 Hunt Road
Orangeburg, NY 10962
P: (845) 589-0580

Account #: 5732
SPL Project ID: 2607-00280
Project Name: Essex County College
Sampled By: James Kelly
Date Received: 07/07/2026
Date Final: 07/24/2026

Location:	1. Room 313 Sink 1	Date Collected:	07/02/2026
Sample ID:	2607-00280.001	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:33 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	0.0014 mg/L		
Location:	2. Room 313 Sink 2	Date Collected:	07/02/2026
Sample ID:	2607-00280.002	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:33 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	<0.0010 mg/L		
Location:	3. Room 314 Sink	Date Collected:	07/02/2026
Sample ID:	2607-00280.003	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:32 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	0.0019 mg/L		
Location:	4. Room 315 Sink	Date Collected:	07/02/2026
Sample ID:	2607-00280.004	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:30 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	0.0016 mg/L		
Location:	5. Room 316 Sink	Date Collected:	07/02/2026
Sample ID:	2607-00280.005	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:26 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	<0.0010 mg/L		



FINAL REPORT

Clarity Water Technologies

87 Hunt Road
Orangeburg, NY 10962
P: (845) 589-0580

Account #: 5732
SPL Project ID: 2607-00280
Project Name: Essex County College
Sampled By: James Kelly
Date Received: 07/07/2026
Date Final: 07/24/2026

Location:	6. Room 316 Sink 2	Date Collected:	07/02/2026
Sample ID:	2607-00280.006	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:26 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	0.0220 mg/L		
Location:	7. Room 317 Sink 1	Date Collected:	07/02/2026
Sample ID:	2607-00280.007	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:24 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	0.0042 mg/L		
Location:	8. Room 317 Sink 2	Date Collected:	07/02/2026
Sample ID:	2607-00280.008	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:24 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	0.0014 mg/L		
Location:	9. Kitchen Sink 1	Date Collected:	07/02/2026
Sample ID:	2607-00280.009	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:22 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	<0.0010 mg/L		
Location:	10. Kitchen Sink 2	Date Collected:	07/02/2026
Sample ID:	2607-00280.010	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:21 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	0.0041 mg/L		



FINAL REPORT

Clarity Water Technologies

87 Hunt Road
Orangeburg, NY 10962
P: (845) 589-0580

Account #: 5732
SPL Project ID: 2607-00280
Project Name: Essex County College
Sampled By: James Kelly
Date Received: 07/07/2026
Date Final: 07/24/2026

Location:	11. Kitchen Sink 3	Date Collected:	07/02/2026
Sample ID:	2607-00280.011	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:21 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	<0.0010 mg/L		
Location:	12. Room 307	Date Collected:	07/02/2026
Sample ID:	2607-00280.012	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:20 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	<0.0010 mg/L		
Location:	13. Room 308 RR Sink	Date Collected:	07/02/2026
Sample ID:	2607-00280.013	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:19 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	0.0051 mg/L		
Location:	14. Room 304 Water Cooler	Date Collected:	07/02/2026
Sample ID:	2607-00280.014	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:15 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	<0.0010 mg/L		
Location:	15. Room 305 Sink	Date Collected:	07/02/2026
Sample ID:	2607-00280.015	Sample Type:	Water
Source Type:	Potable	Time Collected:	10:14 am
Test Requested:	Lead	Status:	Complete 07/24/2026
Result:	Complete		
Concentration:	0.0032 mg/L		



Special Pathogens Laboratory-Building Sciences
1401 Forbes Ave, Suite 401 Pittsburgh, PA 15219
P: 412-281-5335
www.PaceLabs.com



FINAL REPORT

Clarity Water Technologies

87 Hunt Road
Orangeburg, NY 10962
P: (845) 589-0580

Account #: 5732
SPL Project ID: 2607-00280
Project Name: Essex County College
Sampled By: James Kelly
Date Received: 07/07/2026
Date Final: 07/24/2026

Approved By: Erika Egeler

A handwritten signature in black ink, appearing to read 'Michael Berg'.

Dr. Michael Berg
Laboratory Director



FINAL REPORT

Clarity Water Technologies

87 Hunt Road
Orangeburg, NY 10962
P: (845) 589-0580

Account #: 5732
SPL Project ID: 2607-00280
Project Name: Essex County College
Sampled By: James Kelly
Date Received: 07/07/2026
Date Final: 07/24/2026

Report Distribution List:

Legionella@claritywatertech.com,Rharris@claritywatertech.com,claritywater@msn.com,jsheehan@claritywatertech.com,reports@specialpathogenslab.com.

NOTES

Lead

Lead: Concentration in milligrams per liter (mg/L).

-Testing Performed by Pace Analytical Services LLC. Sub-contractor report available upon request.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed. This report is not to be reproduced in whole or in part without the expressed consent of SPL. Results apply to the sample as received.